

December 30, 2020

2020 Annual Compliance Audit

Water System: ALTONA (RED RIVER REGIONAL) - PWS	Code: 4.00
Water System Owner: Town of Altona	Address: Box 1630, Altona, MB R0G0B0
Operating Licence: PWS--08-153-02	Expiry Date: November 30, 2023
Water System Assessment Due Date: March 1, 2026	Compliance Plan Due Date: N/A
Public Water System Annual Report Due Date: March 31, 2021	Advisory Notification Plan Due Date: May 1, 2021

- 1) This report documents compliance of the Altona (Red River Regional) Public Water System for the period from January 1 to December 31, 2020.
- 2) This report provides specific information on the non-compliance incidents identified in the summary below.
- 3) Other than the information provided in this report, the water supplier has complied with The Drinking Water Safety Act, its supporting regulations, and the terms and conditions of the water system's current operating licence.
- 4) This report is based on information submitted by the water supplier, agents of the water supplier, and / or the Province of Manitoba.
- 5) Where non-compliance items are identified, the issues do not necessarily translate into increased public health risk. The Office of Drinking Water uses processes, including boil water advisories, to notify water users of a public health risk.

Non-compliance with Treatment Standards:

Water system was compliant in the audited time period.


Non-compliance Incidents:

*Note failure to submit bacteriological samples at the frequency specified or the required number of samples, results in additional non-compliance with other terms and conditions of the operating licence. This includes the applicable bacteriological standards, disinfection standard and monitoring requirements, and other requirements applicable to the location of the missed sample.

Date	Incident	Outcome
2020-11-17	Failure to meet the trihalomethane standard of less than or equal to 0.10 mg/L	Non-compliant

If you have any questions, please do not hesitate to contact me at (204) 795-6908.

Sincerely,



Kale Black
Senior Regional Drinking Water Officer